

NFRC Product Certification Authorization Report



Manufacturer: Lawson Industries **Product Series:** 9000 Sliding Glass Door **Simulation Lab:** SFTL **Initial Cert. Date:** 06/15/2007
Street: 8501 NW 90th Street **Product Type:** DDSG **Sim. Report #:** 9061-2 **Re-Certification Date:** 08/29/2016
City/State/Zip: Medley, FL 33166 **Air Leakage:** **Sim. Report Date:** 07/13/2016 **Revised Date:** 12/12/2017
Print Date: 08/09/2018 **VR (Standard Screen):** **Test Date:** 07/28/2016 **Expiration Date:** 07/28/2021
VR (Enhanced Screen):

CPD Number: LAW-A-6

IA: American Architectural Manufacturers Association

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00035-00001	3/16 Clear - Air - 3/16 Clear	AL/AL	2		0.250	A8-S	Fill 1: AIR (100)	N		CL	0.69	0.63	0.68	16
	00035-00002	3/16 Green - Air - 3/16 Clear	AL/AL	2		0.250	A8-S	Fill 1: AIR (100)	N		GR	0.69	0.46	0.60	16
	00035-00003	3/16 Bronze - Air - 3/16 Clear	AL/AL	2		0.250	A8-S	Fill 1: AIR (100)	N		BZ	0.69	0.47	0.44	16
	00035-00004	3/16 Gray - Air - 3/16 Clear	AL/AL	2		0.250	A8-S	Fill 1: AIR (100)	N		GY	0.69	0.44	0.38	16
	00036-00001	3/16 E2 - Air - 3/16 Clear	AL/AL	2	0.202(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.62	0.54	0.62	16
	00037-00001	3/16 Clear	AL/AL	1			N		N		CL	1.07	0.72	0.75	12
	00037-00002	3/16 Green	AL/AL	1			N		N		GR	1.07	0.55	0.66	12
	00037-00003	3/16 Bronze	AL/AL	1			N		N		BZ	1.07	0.56	0.49	12
	00037-00004	3/16 Gray	AL/AL	1			N		N		GY	1.07	0.54	0.42	12
	00037-00005	1/4 Clear	AL/AL	1			N		N		CL	1.07	0.70	0.74	12
	00037-00006	1/4 Green	AL/AL	1			N		N		GR	1.07	0.53	0.64	12
	00037-00007	1/4 Bronze	AL/AL	1			N		N		BZ	1.07	0.53	0.45	12
	00037-00008	1/4 Gray	AL/AL	1			N		N		GY	1.07	0.50	0.37	12
	00038-00001	3/16 LoE 366 - Air - 3/16 Clear	AL/AL	2	0.022(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.58	0.25	0.53	16
	00039-00001	3/16 LoE 270 - Air - 3/16 Clear	AL/AL	2	0.037(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.59	0.33	0.57	16
	00040-00001	3/16 LoE 240 - Air - 3/16 Clear	AL/AL	2	0.057(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.59	0.24	0.33	16
	00041-00001	3/16 LoE 366 - Arg - 3/16 Clear	AL/AL	2	0.022(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.53	0.25	0.53	16
	00042-00001	3/16 LoE 270 - Arg - 3/16 Clear	AL/AL	2	0.037(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.53	0.32	0.57	16
	00043-00001	3/16 LoE 240 - Arg - 3/16 Clear	AL/AL	2	0.057(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.54	0.23	0.33	16
	00044-00001	1/8 Comfort Select 28 - Air - 1/ 8 Clear	AL/AL	2	0.021(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.59	0.26	0.53	16
	00045-00001	1/8 Comfort Select 36 - Air - 1/ 8 Clear	AL/AL	2	0.027(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.59	0.32	0.56	16
	00046-00001	1/8 Clima Guard 55/27 - Air - 1/ 8 Clear	AL/AL	2	0.031(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.59	0.26	0.47	16
	00047-00001	1/8 Clima Guard 63/31 - Air - 1/ 8 Clear	AL/AL	2	0.033(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.59	0.28	0.53	16
	00048-00001	1/8 Clima Guard 70/36 - Air - 1/ 8 Clear	AL/AL	2	0.036(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.59	0.31	0.53	16

NFRC Product Certification Authorization Report



Manufacturer: Lawson Industries **Product Series:** 9000 Sliding Glass Door **Simulation Lab:** SFTL **Initial Cert. Date:** 06/15/2007
Street: 8501 NW 90th Street **Product Type:** DDSG **Sim. Report #:** 9061-2 **Re-Certification Date:** 08/29/2016
City/State/Zip: Medley, FL 33166 **Air Leakage:** **Sim. Report Date:** 07/13/2016 **Revised Date:** 12/12/2017
Print Date: 08/09/2018 **VR (Standard Screen):** **Test Date:** 07/28/2016 **Expiration Date:** 07/28/2021
VR (Enhanced Screen):

CPD Number: LAW-A-6 IA: American Architectural Manufacturers Association

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00049-00001	1/8 Comfort Select 28 - Arg - 1/ 8 Clear	AL/AL	2	0.021(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.53	0.26	0.53	16
	00050-00001	1/8 Comfort Select 36 - Arg - 1/ 8 Clear	AL/AL	2	0.027(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.53	0.32	0.56	16
	00051-00001	1/8 Clima Guard 55/27 - Arg - 1/ 8 Clear	AL/AL	2	0.031(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.53	0.25	0.47	16
	00052-00001	1/8 Clima Guard 63/31 - Arg - 1/ 8 Clear	AL/AL	2	0.033(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.53	0.28	0.53	16
	00053-00001	1/8 Clima Guard 70/36 - Arg - 1/ 8 Clear	AL/AL	2	0.036(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.53	0.30	0.53	16
	00054-00001	1/8 LoE 340 - AIR - 1/8 Clear	AL/AL	2	0.028(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.59	0.18	0.33	16
	00054-00002	1/8 LoE 340 - AIR - 1/8 Clear	AL/AL	2	0.028(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.59	0.18	0.33	16
	00054-00003	3/16 LoE 340 - AIR - 3/16 Clear	AL/AL	2	0.028(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.59	0.18	0.32	16
	00054-00004	3/16 LoE 340 - AIR - 3/16 Clear	AL/AL	2	0.028(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.59	0.18	0.32	16
	00055-00001	1/8 LoE 340 - ARG - 1/8 Clear	AL/AL	2	0.028(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.53	0.17	0.33	16
	00055-00002	1/8 LoE 340 - ARG - 1/8 Clear	AL/AL	2	0.028(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.53	0.17	0.33	16
	00055-00003	3/16 LoE 340 - ARG - 3/16 Clear	AL/AL	2	0.028(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.53	0.17	0.32	16
	00055-00004	3/16 LoE 340 - ARG - 3/16 Clear	AL/AL	2	0.028(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.53	0.17	0.32	16
	00056-00001	1/8 Clima Guard 62/27 - AIR - 1/ 8 Clear	AL/AL	2	0.03(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.59	0.26	0.52	16
	00056-00002	1/8 Clima Guard 62/27 - AIR - 1/ 8 Clear	AL/AL	2	0.03(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.59	0.26	0.52	16
	00056-00003	3/16 Clima Guard 62/27 - AIR - 3/16 Clear	AL/AL	2	0.03(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.59	0.26	0.51	16
	00056-00004	3/16 Clima Guard 62/27 - AIR - 3/16 Clear	AL/AL	2	0.03(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.59	0.26	0.51	16
	00057-00001	1/8 Clima Guard 62/27 - ARG - 1/ 8 Clear	AL/AL	2	0.03(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.53	0.25	0.52	16
	00057-00002	1/8 Clima Guard 62/27 - ARG - 1/ 8 Clear	AL/AL	2	0.03(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.53	0.25	0.52	16
	00057-00003	3/16 Clima Guard 62/27 - ARG - 3/16 Clear	AL/AL	2	0.03(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.53	0.25	0.51	16
	00057-00004	3/16 Clima Guard 62/27 - ARG - 3/16 Clear	AL/AL	2	0.03(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.53	0.25	0.51	16
	00058-00001	3/16 Neutral 40 - AIR - 3/16 Clear	AL/AL	2	0.149(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.61	0.29	0.34	16

NFRC Product Certification Authorization Report



Manufacturer: Lawson Industries **Product Series:** 9000 Sliding Glass Door **Simulation Lab:** SFTL **Initial Cert. Date:** 06/15/2007
Street: 8501 NW 90th Street **Product Type:** DDSG **Sim. Report #:** 9061-2 **Re-Certification Date:** 08/29/2016
City/State/Zip: Medley, FL 33166 **Air Leakage:** **Sim. Report Date:** 07/13/2016 **Revised Date:** 12/12/2017
Print Date: 08/09/2018 **VR (Standard Screen):** **Test Date:** 07/28/2016 **Expiration Date:** 07/28/2021
VR (Enhanced Screen):

CPD Number: LAW-A-6			IA: American Architectural Manufacturers Association												
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00058-00002	3/16 Neutral 40 - AIR - 3/16 Clear	AL/AL	2	0.149(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.61	0.29	0.34	16
	00059-00001	3/16 Neutral 40 - ARG - 3/16 Clear	AL/AL	2	0.149(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.56	0.29	0.34	16
	00059-00002	3/16 Neutral 40 - ARG - 3/16 Clear	AL/AL	2	0.149(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.56	0.29	0.34	16

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TFTL	07/28/2016	2000 mm x 2000 mm	0.581	0.540	9018

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA
Signature: _____