

# NFRC Product Certification Authorization Report



<b>Manufacturer:</b> Lawson Industries	<b>Product Series:</b> 9200 Sliding Glass Door	<b>Simulation Lab:</b> SFTL	<b>Initial Cert. Date:</b> 06/20/2007
<b>Street:</b> 8501 NW 90th Street	<b>Product Type:</b> DDSG	<b>Sim. Report #:</b> 9062-REV01	<b>Re-Certification Date:</b> 08/29/2016
<b>City/State/Zip:</b> Medley, FL 33166	<b>Air Leakage:</b>	<b>Sim. Report Date:</b> 07/15/2016	<b>Revised Date:</b> 09/19/2016
<b>Print Date:</b> 09/29/2016		<b>Test Date:</b> 07/27/2016	<b>Expiration Date:</b> 07/27/2021

CPD Number: LAW-A-9

IA: American Architectural Manufacturers Association

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00005-00001	3/16 Bronze-090 PVB -3/16 Clear	AL/AS	1			N		N		BR	1.01	0.50	0.47	15
	00005-00002	3/16 Clear-090 PVB-3/16 Clear	AL/AS	1			N		N		CL	1.01	0.62	0.71	15
	00005-00003	3/16 Gray-090 PVB-3/16 Clear	AL/AS	1			N		N		GY	1.01	0.48	0.40	15
	00005-00004	3/16 Clear-090 Gray PVB-3/16 Clear	AL/AS	1			N		N		GY	1.01	0.39	0.09	15
	00005-00005	3/16 Clear-090 Bronze PVB-3/16 Clear	AL/AS	1			N		N		BZ	1.01	0.36	0.12	15
	00006-00001	3/16 Clear-090 PVB-3/16 Clear i89	AL/AS	1	0.149(2)		N		N		CL	0.73	0.55	0.70	10
	00006-00002	3/16 Bronze-090 PVB-3/16 Clear i89	AL/AS	1	0.149(2)		N		N		BZ	0.73	0.42	0.46	10
	00006-00003	3/16 Gray-090 PVB-3/16 Clear i89	AL/AS	1	0.149(2)		N		N		GY	0.73	0.40	0.39	10
	00007-00001	3/16 LoE 366-090 SGP - 3/16 Clear	AL/AS	1			N		N		CL	1.02	0.30	0.49	15

---

**Baseline Information**

<b>Test Lab</b>	<b>Test Date</b>	<b>Test Size</b>	<b>Tested U-Value</b>	<b>Standard U-Value</b>	<b>Test Report Number</b>
<b>TFTL</b>	<b>07/27/2016</b>	2000 mm x 2000 mm	0.898	0.795	9019

**Comments:**

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA  
Signature: \_\_\_\_\_