

# NFRC Product Certification Authorization Report



**Manufacturer:** Lawson Industries  
**Street:** 8501 NW 90th Street  
**City/State/Zip:** Medley, FL 33166

**Product Series:** 4000/6000 Fixed Window  
**Product Type:** FIXD  
**Air Leakage:**

**Simulation Lab:** SFTL  
**Sim. Report #:** 12798  
**Sim. Report Date:** 09/10/2021

**Initial Cert. Date:** 04/13/2022  
**Re-Certification Date:**  
**Revised Date:** 01/01/1970

**Print Date:** 07/11/2022

**Test Date:** 09/12/2021

**Expiration Date:** 09/12/2026

CPD Number: LAW-M-20

IA: National Accreditation And Management Institute

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00001-00001	1/8 Gray - Air - 1/8 Clear	AL/N	2		0.250	A8-S	Fill 1: AIR(100)	N		GY	0.63	0.57	0.52	17
	00001-00002	1/8 Gray - Air - 1/8 Clear	AL/N	2		0.250	P1-S	Fill 1: AIR(100)	N		GY	0.63	0.57	0.52	17
	00001-00003	1/8 Clear - Air - 1/8 Clear	AL/N	2		0.250	A8-S	Fill 1: AIR(100)	N		CL	0.63	0.73	0.77	17
	00001-00004	1/8 Clear - Air - 1/8 Clear	AL/N	2		0.250	P1-S	Fill 1: AIR(100)	N		CL	0.63	0.73	0.77	17
	00001-00005	1/8 Green - Air - 31/8 Clear	AL/N	2		0.250	A8-S	Fill 1: AIR(100)	N		GR	0.63	0.57	0.70	17
	00001-00006	1/8 Green - Air - 31/8 Clear	AL/N	2		0.250	P1-S	Fill 1: AIR(100)	N		GR	0.63	0.57	0.70	17
	00001-00007	1/8 Bronze - Air - 1/8 Clear	AL/N	2		0.250	A8-S	Fill 1: AIR(100)	N		BZ	0.63	0.59	0.57	17
	00001-00008	1/8 Bronze - Air - 1/8 Clear	AL/N	2		0.250	P1-S	Fill 1: AIR(100)	N		BZ	0.63	0.59	0.57	17
	00002-00001	1/8 Comfort E2 - Air - 1/8 Clear	AL/N	2	0.204(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.55	0.62	0.70	18
	00002-00002	1/8 Comfort E2 - Air - 1/8 Clear	AL/N	2	0.204(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.55	0.62	0.70	18
	00003-00001	1/8 Clear	AL/N	1			N		N		CL	1.08	0.81	0.84	12
	00003-00002	1/8 Green	AL/N	1			N		N		GR	1.08	0.66	0.77	12
	00003-00003	1/8 Bronze	AL/N	1			N		N		BZ	1.08	0.68	0.63	12
	00003-00004	1/8 Gray	AL/N	1			N		N		GY	1.08	0.66	0.58	12
	00003-00005	3/16 Clear	AL/N	1			N		N		CL	1.08	0.79	0.83	12
	00003-00006	3/16 Green	AL/N	1			N		N		GR	1.08	0.61	0.74	12
	00003-00007	3/16 Bronze	AL/N	1			N		N		BZ	1.08	0.62	0.54	12
	00003-00008	3/16 Gray	AL/N	1			N		N		GY	1.08	0.59	0.47	12
	00003-00009	1/4 Clear	AL/N	1			N		N		CL	1.08	0.78	0.83	12
	00003-00010	1/4 Green	AL/N	1			N		N		GR	1.08	0.58	0.72	12
	00003-00011	1/4 Bronze	AL/N	1			N		N		BZ	1.08	0.59	0.50	12
	00003-00012	1/4 Gray	AL/N	1			N		N		GY	1.08	0.56	0.42	12
	00004-00001	1/8 LoE 366 - Air - 1/8 Clear	AL/N	2	0.022(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.51	0.27	0.60	18
	00004-00002	1/8 LoE 366 - Air - 1/8 Clear	AL/N	2	0.022(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.51	0.27	0.60	18

# NFRC Product Certification Authorization Report



**Manufacturer:** Lawson Industries      **Product Series:** 4000/6000 Fixed Window      **Simulation Lab:** SFTL      **Initial Cert. Date:** 04/13/2022  
**Street:** 8501 NW 90th Street      **Product Type:** FIXD      **Sim. Report #:** 12798      **Re-Certification Date:**  
**City/State/Zip:** Medley, FL 33166      **Air Leakage:**      **Sim. Report Date:** 09/10/2021      **Revised Date:** 01/01/1970  
**Print Date:** 07/11/2022      **Test Date:** 09/12/2021      **Expiration Date:** 09/12/2026

CPD Number: LAW-M-20															IA: National Accreditation And Management Institute	
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.	
	00004-00003	3/16 LoE 366 - Air - 3/16 Clear	AL/N	2	0.022(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.51	0.27	0.59	18	
	00004-00004	3/16 LoE 366 - Air - 3/16 Clear	AL/N	2	0.022(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.51	0.27	0.59	18	
	00005-00001	1/8 LoE 270 - Air - 1/8 Clear	AL/N	2	0.037(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.36	0.65	18	
	00005-00002	1/8 LoE 270 - Air - 1/8 Clear	AL/N	2	0.037(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.36	0.65	18	
	00005-00003	3/16 LoE 270 - Air - 3/16 Clear	AL/N	2	0.037(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.35	0.64	18	
	00005-00004	3/16 LoE 270 - Air - 3/16 Clear	AL/N	2	0.037(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.35	0.64	18	
	00006-00001	1/8 LoE 240 - Air - 1/8 Clear	AL/N	2	0.057(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.26	0.37	18	
	00006-00002	1/8 LoE 240 - Air - 1/8 Clear	AL/N	2	0.057(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.26	0.37	18	
	00006-00003	3/16 LoE 240 - Air - 3/16 Clear	AL/N	2	0.057(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.26	0.36	18	
	00006-00004	3/16 LoE 240 - Air - 3/16 Clear	AL/N	2	0.057(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.26	0.36	18	
	00007-00001	1/8 LoE 366 - Arg - 1/8 Clear	AL/N	2	0.022(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.27	0.60	18	
	00007-00002	1/8 LoE 366 - Arg - 1/8 Clear	AL/N	2	0.022(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.27	0.60	18	
	00007-00003	3/16 LoE 366 - Arg - 3/16 Clear	AL/N	2	0.022(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.27	0.34	18	
	00007-00004	3/16 LoE 366 - Arg - 3/16 Clear	AL/N	2	0.022(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.27	0.34	18	
	00008-00001	1/8 LoE 270 - Arg - 1/8 Clear	AL/N	2	0.037(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.35	0.65	18	
	00008-00002	1/8 LoE 270 - Arg - 1/8 Clear	AL/N	2	0.037(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.35	0.65	18	
	00008-00003	3/16 LoE 270 -Arg - 3/16 Clear	AL/N	2	0.037(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.35	0.64	18	
	00008-00004	3/16 LoE 270 -Arg - 3/16 Clear	AL/N	2	0.037(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.35	0.64	18	
	00009-00001	1/8 LoE 240- Arg - 1/8 Clear	AL/N	2	0.057(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.25	0.37	18	
	00009-00002	1/8 LoE 240- Arg - 1/8 Clear	AL/N	2	0.057(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.25	0.37	18	
	00009-00003	3/16 LoE 240 - Arg - 3/16 Clear	AL/N	2	0.057(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.25	0.36	18	
	00009-00004	3/16 LoE 240 - Arg - 3/16 Clear	AL/N	2	0.057(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.25	0.36	18	
	00010-00001	1/8 Comfort Select 28 - Air - 1/8 Clear	AL/N	2	0.021(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.51	0.28	0.59	18	
	00010-00002	1/8 Comfort Select 28 - Air - 1/8 Clear	AL/N	2	0.021(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.51	0.28	0.59	18	
	00010-00003	3/16 Comfort Select 28 - Air - 3/16 Clear	AL/N	2	0.021(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.51	0.28	0.58	18	

# NFRC Product Certification Authorization Report



**Manufacturer:** Lawson Industries      **Product Series:** 4000/6000 Fixed Window      **Simulation Lab:** SFTL      **Initial Cert. Date:** 04/13/2022  
**Street:** 8501 NW 90th Street      **Product Type:** FIXD      **Sim. Report #:** 12798      **Re-Certification Date:**  
**City/State/Zip:** Medley, FL 33166      **Air Leakage:**      **Sim. Report Date:** 09/10/2021      **Revised Date:** 01/01/1970  
**Print Date:** 07/11/2022      **Test Date:** 09/12/2021      **Expiration Date:** 09/12/2026

CPD Number: LAW-M-20															IA: National Accreditation And Management Institute	
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.	
	00010-00004	3/16 Comfort Select 28 - Air - 3/16 Clear	AL/N	2	0.021(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.51	0.28	0.58	18	
	00011-00001	1/8 Comfort Select 36 - Air - 1/8 Clear	AL/N	2	0.027(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.35	0.62	18	
	00011-00002	1/8 Comfort Select 36 - Air - 1/8 Clear	AL/N	2	0.027(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.35	0.62	18	
	00011-00003	3/16 Comfort Select 36 - Air - 3/16 Clear	AL/N	2	0.026(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.35	0.61	18	
	00011-00004	3/16 Comfort Select 36 - Air - 3/16 Clear	AL/N	2	0.026(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.35	0.61	18	
	00012-00001	1/8 Clima Guard 55/27 - Air - 1/8 Clear	AL/N	2	0.031(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.28	0.52	18	
	00012-00002	1/8 Clima Guard 55/27 - Air - 1/8 Clear	AL/N	2	0.031(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.28	0.52	18	
	00012-00003	3/16 Clima Guard 55/27 - Air - 3/16 Clear	AL/N	2	0.031(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.28	0.51	18	
	00012-00004	3/16 Clima Guard 55/27 - Air - 3/16 Clear	AL/N	2	0.031(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.28	0.51	18	
	00013-00001	1/8 Clima Guard 63/31 - Air - 1/8 Clear	AL/N	2	0.033(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.31	0.58	18	
	00013-00002	1/8 Clima Guard 63/31 - Air - 1/8 Clear	AL/N	2	0.033(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.31	0.58	18	
	00013-00003	3/16 Clima Guard 63/31 - Air - 3/16 Clear	AL/N	2	0.033(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.31	0.58	18	
	00013-00004	3/16 Clima Guard 63/31 - Air - 3/16 Clear	AL/N	2	0.033(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.31	0.58	18	
	00014-00001	1/8 Clima Guard 70/36 - Air - 1/8 Clear	AL/N	2	0.036(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.37	0.65	18	
	00014-00002	1/8 Clima Guard 70/36 - Air - 1/8 Clear	AL/N	2	0.036(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.37	0.65	18	
	00014-00003	3/16 Clima Guard 70/36 - Air - 3/16 Clear	AL/N	2	0.036(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.37	0.64	18	
	00014-00004	3/16 Clima Guard 70/36 - Air - 3/16 Clear	AL/N	2	0.036(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.37	0.64	18	
	00015-00001	1/8 Comfort Select 28 - Arg - 1/8 Clear	AL/N	2	0.021(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.28	0.59	18	
	00015-00002	1/8 Comfort Select 28 - Arg - 1/8 Clear	AL/N	2	0.021(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.28	0.59	18	
	00015-00003	3/16 Comfort Select 28 - Arg - 3/16 Clear	AL/N	2	0.021(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.28	0.58	18	
	00015-00004	3/16 Comfort Select 28 - Arg - 3/16 Clear	AL/N	2	0.021(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.28	0.58	18	
	00016-00001	1/8 Comfort Select 36 - Arg - 1/8 Clear	AL/N	2	0.027(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.35	0.62	18	

# NFRC Product Certification Authorization Report



**Manufacturer:** Lawson Industries      **Product Series:** 4000/6000 Fixed Window      **Simulation Lab:** SFTL      **Initial Cert. Date:** 04/13/2022  
**Street:** 8501 NW 90th Street      **Product Type:** FIXD      **Sim. Report #:** 12798      **Re-Certification Date:**  
**City/State/Zip:** Medley, FL 33166      **Air Leakage:**      **Sim. Report Date:** 09/10/2021      **Revised Date:** 01/01/1970  
**Print Date:** 07/11/2022      **Test Date:** 09/12/2021      **Expiration Date:** 09/12/2026

CPD Number: LAW-M-20															IA: National Accreditation And Management Institute	
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.	
	00016-00002	1/8 Comfort Select 36 - Arg - 1/8 Clear	AL/N	2	0.027(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.35	0.62	18	
	00016-00003	3/16 Comfort Select 36 - Arg - 3/16 Clear	AL/N	2	0.026(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.35	0.61	18	
	00016-00004	3/16 Comfort Select 36 - Arg - 3/16 Clear	AL/N	2	0.026(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.35	0.61	18	
	00017-00001	1/8 Clima Guard 55/27 - Arg - 1/8 Clear	AL/N	2	0.031(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.27	0.52	18	
	00017-00002	1/8 Clima Guard 55/27 - Arg - 1/8 Clear	AL/N	2	0.031(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.27	0.52	18	
	00017-00003	3/16 Clima Guard 55/27 - Arg - 3/16 Clear	AL/N	2	0.031(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.27	0.51	18	
	00017-00004	3/16 Clima Guard 55/27 - Arg - 3/16 Clear	AL/N	2	0.031(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.27	0.51	18	
	00018-00001	1/8 Clima Guard 63/31 - Arg - 1/8 Clear	AL/N	2	0.033(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.30	0.58	18	
	00018-00002	1/8 Clima Guard 63/31 - Arg - 1/8 Clear	AL/N	2	0.033(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.30	0.58	18	
	00018-00003	3/16 Clima Guard 63/31 - Arg - 3/16 Clear	AL/N	2	0.033(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.30	0.58	18	
	00018-00004	3/16 Clima Guard 63/31 - Arg - 3/16 Clear	AL/N	2	0.033(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.30	0.58	18	
	00019-00001	1/8 Clima Guard 70/36 - Arg - 1/8 Clear	AL/N	2	0.036(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.37	0.65	18	
	00019-00002	1/8 Clima Guard 70/36 - Arg - 1/8 Clear	AL/N	2	0.036(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.37	0.65	18	
	00019-00003	3/16 Clima Guard 70/36 - Arg - 3/16 Clear	AL/N	2	0.036(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.36	0.64	18	
	00019-00004	3/16 Clima Guard 70/36 - Arg - 3/16 Clear	AL/N	2	0.036(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.36	0.64	18	
	00020-00001	1/8 LoE 340 - Air - 1/8 Clear	AL/N	2	0.028(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.19	0.36	18	
	00020-00002	1/8 LoE 340 - Air - 1/8 Clear	AL/N	2	0.028(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.19	0.36	18	
	00020-00003	3/16 LoE 340 - Air - 3/16 Clear	AL/N	2	0.028(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.52	0.20	0.36	18	
	00020-00004	3/16 LoE 340 - Air - 3/16 Clear	AL/N	2	0.028(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.52	0.20	0.36	18	
	00021-00001	1/8 LoE 340 - Arg - 1/8 Clear	AL/N	2	0.028(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.18	0.36	18	
	00021-00002	1/8 LoE 340 - Arg - 1/8 Clear	AL/N	2	0.028(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.18	0.36	18	
	00021-00003	3/16 LoE 340 - Arg - 3/16 Clear	AL/N	2	0.028(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.19	0.36	18	

# NFRC Product Certification Authorization Report



**Manufacturer:** Lawson Industries      **Product Series:** 4000/6000 Fixed Window      **Simulation Lab:** SFTL      **Initial Cert. Date:** 04/13/2022  
**Street:** 8501 NW 90th Street      **Product Type:** FIXD      **Sim. Report #:** 12798      **Re-Certification Date:**  
**City/State/Zip:** Medley, FL 33166      **Air Leakage:**      **Sim. Report Date:** 09/10/2021      **Revised Date:** 01/01/1970  
**Print Date:** 07/11/2022      **Test Date:** 09/12/2021      **Expiration Date:** 09/12/2026

CPD Number: LAW-M-20			IA: National Accreditation And Management Institute												
Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00021-00004	3/16 LoE 340 - Arg - 3/16 Clear	AL/N	2	0.028(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.19	0.36	18
	00022-00001	1/8 SunGuard 62/27 - Air - 1/8 Clear	AL/N	2	0.03(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.51	0.26	0.57	18
	00022-00002	1/8 SunGuard 62/27 - Air - 1/8 Clear	AL/N	2	0.03(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.51	0.26	0.57	18
	00022-00003	3/16 SunGuard 62/27 - Air - 3/16 Clear	AL/N	2	0.03(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.51	0.26	0.56	18
	00022-00004	3/16 SunGuard 62/27 - Air - 3/16 Clear	AL/N	2	0.03(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.51	0.26	0.56	18
	00023-00001	1/8 SunGuard 62/27 - Arg - 1/8 Clear	AL/N	2	0.03(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.25	0.57	18
	00023-00002	1/8 SunGuard 62/27 - Arg - 1/8 Clear	AL/N	2	0.03(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.25	0.57	18
	00023-00003	3/16 SunGuard 62/27 - Arg - 3/16 Clear	AL/N	2	0.03(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.25	0.56	18
	00023-00004	3/16 SunGuard 62/27 - Arg - 3/16 Clear	AL/N	2	0.03(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.45	0.25	0.56	18
	00024-00001	3/16 SunGuard Neutral 40 - Air - 3/16 Clear	AL/N	2	0.149(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.55	0.32	0.37	19
	00024-00002	3/16 SunGuard Neutral 40 - Air - 3/16 Clear	AL/N	2	0.149(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.55	0.32	0.37	19
	00025-00001	3/16 SunGuard Neutral 40 - Arg - 3/16 Clear	AL/N	2	0.149(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.49	0.31	0.37	19
	00025-00002	3/16 SunGuard Neutral 40 - Arg - 3/16 Clear	AL/N	2	0.149(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.49	0.31	0.37	19

---

**Baseline Information**

<b>Test Lab</b>	<b>Test Date</b>	<b>Test Size</b>	<b>Tested U-Value</b>	<b>Standard U-Value</b>	<b>Test Report Number</b>
TFTL	09/12/2021	1200mm x 1500mm	0.485	0.467	12699

**Comments:**

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA  
Signature: \_\_\_\_\_

